

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7270-1429:116 Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** Secutron, Div. of Digital Security Controls LTD, 3301 Langstaff Rd, Ontario Canada L4k 4L2  
Contact: Paul Mattern (978) 731-8542 Fax (978) 731-8881

**DESIGN:** Model MRI-525IB (fixed temperature) electronic heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 135° F fixed temperature

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings, and UL Label.

**APPROVAL:** Listed as a heat detector for use with System Sensor's Model B501 or B210LP base (CSFM Listing No. 7300-1209:128) and separately listed compatible fire alarm control units. Refer to listee's Installation Instructions Manual for details

**XLF:** 7270-1209:193

04-14-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 14, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**